

Non-contact liquid level sensor instruction manual

(Intelligent external paste type detection liquid position series products)

XKC-Y28-NO

table of Contents

1st. Overview	2
2nd. Product Features	2
3rd. Product Applications	2
4th. Product parameter	3
5th. product selection	3
6th. Clearance requirements	4
7th. Installation method	4
8th. Sensitivity adjustment:	6
9th. Y28 wiring diagram of various models	6
10th. Product size and physical map	8
11th. Other matters needing attention	8
12th. Troubleshooting:	9
13th. Product warranty terms and instructions	9
14th. Manual version	11



1st. Overview

The intelligent non-contact liquid level sensor (hereinafter referred to as the liquid level sensor) adopts advanced signal processing technology and high-speed signal processing chip, which breaks through the influence of the container wall thickness and realizes the true non-contact of the liquid level in the closed container. Contact detection. The liquid level sensor (probe) is installed on the upper and lower sides of the outer wall of the container to be tested (the high and low levels of the liquid level). The non-metallic container does not need to be opened, and the installation is simple and does not affect production. It can detect the level of various toxic substances, strong acids, strong alkalis and various liquids in high-pressure airtight containers. The liquid level sensor has no special requirements for the material of the liquid medium and container, and can be widely used.

XKC-Y28-NO/NC/ RS485 products are specially developed for non-metallic pipes (pipe outer diameter $D \geq 11\text{MM}$) or flat container liquid level detection. They are relay normally open output and relay normally closed output and RS485 interface output.

2nd. Product Features

1. XCK-Y28-NO/NC/ RS485 sensor, suitable for non-metallic pipes (pipe outer diameter $D \geq 11\text{MM}$) or flat containers without direct contact with liquids, It will not be corroded by strong acids or alkalis and other corrosive liquids, and will not be affected by scale or other debris. It can be completed to detect whether there is liquid inside the container or pipeline.
2. Intelligent liquid level reference adjustment and liquid level memory function, liquid level status display mode, can realize multi-point series connection.
3. The detection is accurate and stable, and the boiling water level can be detected.
4. Pure electronic circuit structure, non-mechanical working mode, stable performance and durability.
5. High stability, high sensitivity, strong anti-interference ability, free from external electromagnetic interference, special treatment for power frequency interference and common mode interference, to be compatible with all 5V, 12V, 24V power adapters on the market.
6. Strong compatibility, penetrating various non-metallic container pipes, such as plastic, glass, ceramics and other containers, the induction pipe wall thickness can reach 20mm; suitable for all kinds of curved, arc, cylindrical containers or pipes Liquid level detection.
7. The voltage can be selected (5V, 12V, 24V), suitable for connecting various circuits and product applications.

3rd. Product Applications

The intelligent non-contact liquid level sensor uses the inductive capacitance of water to detect whether there is liquid. When there is no liquid close to the sensor, the sensor has a certain static capacitance to the ground due to the distributed capacitance on the sensor. When the liquid level slowly rises and approaches the sensor, the parasitic capacitance of the liquid will be coupled to this static capacitance, making the capacitance value of the sensor larger, and the changed capacitance signal is then input to the control IC for signal conversion. The capacitance is converted into a change of a certain electrical signal, and then a certain algorithm is used to detect and judge the degree of this change. When the change exceeds a certain threshold, it is considered that the liquid level has reached the sensing point.

4th.Product parameter


Project name	Parameters	
Product model	XKC-Y28-NO	
Supply voltage (Vin)	5V、12V、24V	
Output mode	Normally open	
electric current	13mA	
The output current	DC24V/2A	
Response time	500mS	
Working temperature	-20~105°C	
Sensor sensitivity	Outer diameter of pipe D(mm)	Sense container wall or tube wall thickness L(mm)
	D≥100	20 ± 3
	100>D≥80	15 ± 2
	80>D≥60	12 ± 1.5
	60>D≥40	7 ± 1.0
	40>D≥30	5 ± 1.0
	30>D≥20	3 ± 1.0
	20>D≥10	1.5 ± 0.5
Applicable pipe diameter range	≥11mm	
Liquid level accuracy	±1.5mm	
humidity	5%~100%	
Line length	500MM (±10MM) (Bulk can be customized)	
Terminal sequence	Brown (power supply positive), yellow (signal output) Blue (power negative), black (COM terminal)	
Material	PC-V0 fireproof material	
Waterproof performance	IP67	
Safety standard certification	CE	
Environmental protection certification	ROHS2.0	

5th.product selection

- Normally open output interface ————— Model: XKC-Y28-NO (DC 5V)
 Normally open output interface ————— Model: XKC-Y28-NO (DC 12V)
 Normally open output interface ————— Model: XKC-Y28-NO (DC 24V)


6th. Clearance requirements

Requirements for the clearance between the contact surface of the sensor (or probe) and the outer wall of the container
 The contact surface of the sensor (or probe) and the outer wall of the container should be tightly pasted with AB or other solid-resistant glue. If there are special requirements, the gap should be less than 0.5mm, preferably no gap, otherwise it may affect the measurement accuracy .




7th. Installation method

Install into a flat cistern as shown in the figure below



How to install to the water pipe



Install to the non-metal water pipe type as shown below

The height of the sensed liquid level is related to the sensitivity of the sensor. The higher the sensitivity, the lower the sensed liquid level


Note: The liquid level is sensed in the upper and lower edges of the sensor, which is normal.

The induction sheet can be tightly attached to the pipe with strong glue, or it can be tightened with the pipe with a nylon cable tie. The part where the probe is installed cannot be made of metal parts, so as not to affect the detection. Pipes made of non-metallic materials with flat surface, uniform thickness, tight material, and good insulation performance; such as glass pipes, plastic pipes, PC/PVC pipes, non-absorbent ceramic pipes, acrylic pipes, rubber pipes, etc. or other composite materials into the pipeline.

8th. Sensitivity adjustment:


If the non-contact liquid level sensor cannot detect or the detected liquid level deviates from the Y28 sensor, The sensitivity knob can be adjusted with a small screwdriver. Setting method:

1. Turn counterclockwise to increase sensitivity.
2. Turn clockwise to lower the sensitivity.




9th. Y28 wiring diagram of various models


XKC-Y28-NO output principle and wiring method



Wiring port definition




Terminal wiring sequence



Wiring method for connecting PLC or MCU:


NPN input type: COM terminal connected to GND

PNP input type: COM terminal connected to VCC



PNP signal output:

Wiring method of connecting relay



NPN signal output:

Wiring method of connecting indicator light

Product Applications of relay NO point output:

1. When the black wire is connected to VCC:

When the liquid is sensed, the relay is closed, the NO point of the relay is turned on, and the VCC voltage is output;


When no liquid is sensed, the relay is disconnected, and the relay NO point is disconnected.

2. When the black wire is connected to GND:

When liquid is sensed, the relay is closed, the NO point of the relay is turned on, and the GND voltage is output;

When no liquid is sensed, the relay is disconnected, and the relay NO point is isconnected.

10th. Product size and physical map



Terminal model: XH2.54-4P

11th. Other matters needing attention

(1) The viscosity of the measured liquid medium

When the dynamic viscosity is less than 10mPaS, it is measured normally. $10\text{mPaS} < \text{dynamic viscosity} < 30\text{mPaS}$ may affect the detection. When the dynamic viscosity is greater than 30mPaS, it cannot be measured because a large amount of liquid adheres to the container wall.

(2) Note: As the temperature increases, the viscosity decreases, and most high-viscosity liquids are more affected by temperature. Therefore, pay attention to the influence of liquid temperature when measuring viscous liquids.

- (3) Pay attention to keeping the sensor clean, try to prevent corrosion and avoid violent collisions and blows from other objects.
- (4) During outdoor installation, avoid direct sunlight and rainwater directly flowing to the main body of the sensor, and keep away from high heat sources and pay attention to ventilation. If the ambient temperature exceeds the rated temperature, corresponding cooling protection measures should be taken.
- (5) When the ambient temperature is lower than the normal operating temperature range of the sensor, an instrument protection box or other protective rain cap devices can be used for antifreeze protection, and pay attention to keeping the sensor dry. The sensor should be regularly maintained and inspected. (The detection time interval is determined by the use unit according to the specific situation).

12th.Troubleshooting:

Fault status	Analyze the reasons	Problem solving measures
After the liquid level sensor is energized, there is no response (the indicator light does not light when the water level reaches the sensing point, and the sensitivity adjustment has no response)	①The power cord is not connected	Check and connect the power
	② The positive and negative ends of the power cord are reversed	Correct wiring
	③The power module is damaged	Replace the circuit board where the power module is located
	④Sensitivity is too low	Adjust the sensitivity to the appropriate gear
The indicator light keeps on	①Sensitivity grade is too high	Adjust the sensitivity to the appropriate grade
	②The initialization parameters are abnormally modified	Return to the factory to reinitialize
	③The sensor has debris or other metal parts close to it	Clean up debris and keep a certain distance from metal parts

13th.Product warranty terms and instructions

(A) .Warranty service

1. Warranty period maintenance: from the date of purchase, the product host has a one-year free warranty. The company has the right to decide to repair or replace the faulty part. If it is replaced, the replacement part may be a new device or a repair product of the same category, function, and quality. The replaced faulty part belongs to the company; the product Resale and repair do not affect the warranty period. Products that have been repaired or replaced continue to enjoy the original remaining warranty period service. If the warranty period is less than three months after the repair, the repaired or replaced part shall be shipped from the date of delivery Warranty for three months; all products of the company are guaranteed for repair.

2. Loss upon arrival (DOA) replacement: From the day of purchase, you can enjoy a free replacement service within 7 days. Products with the following problems are defined as DOA equipment: the packing and packing list do not match

after the first unpacking of the product; some or all of the components cannot be used normally after the first unpacking of the product (surface scratches or other things that do not affect the function of the device) Defects are not included); other hardware failures identified by our company's engineers remotely or locally.

(B). Applicable limitations of warranty

For the following situations, the company does not assume warranty responsibility:

1. The product is out of warranty; the surface of the product is fragile and damaged; the appearance of the product is seriously damaged, installation/use in abnormal environment, unauthorized disassembly and repair/modification, external power supply damage and other abnormal damage;
2. Damage caused by incorrect installation and use of the product by the user not following the requirements of the manual;
3. Damage caused by natural disasters and human negligence (fire, lightning, flooding, impact, etc.).

(C) .Accessories and consumables are not covered by the warranty.

(D) .Non-free warranty service

Within two years of product purchase, for non-warranty product (including components) failures and damages, you can choose paid maintenance services (free labor costs), and we will charge the transportation cost of repairing parts and accessories according to the actual situation.

(E). Ways to obtain warranty service

It is recommended that you contact the dealer who purchased this product to obtain the warranty service. For the warranty, please present a valid warranty card (the dealer's stamp is required to take effect) or the purchase invoice/receipt: if you can't show it, the product's free warranty period 12 months from the product shipment date, and the latest DOA application deadline is 7 days from the product shipment date.

(F). Statement

1. The copyright of this manual belongs to Shenzhen Xingkechuang Technology Co., Ltd. (Xingkechuang) and its authorized licensors. Shenzhen Xingkechuang Technology Co., Ltd. (Xingkechuang) reserves all rights.
2. Without the written permission of the company, no unit or individual may excerpt or copy part or all of the contents of this manual, and shall not spread it in any form.
3. The customer recognizes that the purpose of the design and production of the company's products does not involve use in products related to life support or other systems or products used in other dangerous activities or environments. Personal injury or death, property or environmental damage due to product failure (collectively referred to as high-risk activities). The company's products are artificially used in high-risk activities, and the company does not guarantee it and is not liable to customers or third parties.
4. Due to product version upgrades or other reasons, the contents of this manual may change. Xingkechuang reserves the right to modify the contents of this manual without any notice or prompt. This manual is only used as a guide. Xingkechuang makes every effort to provide accurate information in this manual. However, Xingkechuang does not guarantee that the contents of the manual are completely free of errors. All statements, information and suggestions in this manual do not constitute any express or Implied guarantee.
5. Not all models are available in all countries/regions

Please keep this manual properly. Before using the product, please read this manual carefully. When using the product, please be sure to operate in accordance with this manual. The company is not responsible for injuries and accidents

caused by operations that do not follow this manual.

(G).Environmental protection This product meets the design requirements for environmental protection.The storage, use and disposal should comply with relevant national laws and regulations.Seek to proceed.

14th. Manual version

Version	Release date
V17	May 22, 2023